

令和5年度排ガス濃度

測定日	報告年月日	運転炉	ばいじん (g/m ³)	窒素酸化物 (ppm)	硫黄酸化物 (ppm)	塩化水素 (ppm)	排ガス量(乾) m ³ /h	全水銀 (mg/m ³)
(協定値)			0.02	70	25	50		(0.05)
R05.04.11	R05.04.28	1	<0.002	33	2	<2	29000	-
		2	0.002	25	1	<2	28000	-
R05.05.09	R05.05.24	1	0.005	33	<1	3	27000	-
		2	<0.002	41	2	<2	26000	-
R05.06.06	R05.06.19	1	<0.002	37	<1	2	26000	0.0003
		2	<0.002	37	<1	7	27000	-
R05.07.11	R05.07.24	1	<0.002	39	<1	2	26000	-
		2	<0.002	32	<1	8	24000	0.00015
R05.08.08	R05.08.29	2	<0.002	31	<1	2	23000	-
		3	<0.002	39	<1	<2	23000	0.00012
R05.09.05	R05.09.15	2	<0.002	41	1	<2	25000	-
		3	<0.002	38	<1	2	24000	-
R05.10.30	R05.11.15	1	<0.002	39	3	<2	26000	-
		3	<0.002	43	<1	<2	27000	-
R05.11.13	R05.11.27	1	<0.002	33	1	4	27000	-
		3	<0.002	46	<1	3	27000	-
R05.12.05	R05.12.20	1	<0.002	39	<1	4	29000	0.001
		3	<0.002	46	<1	5	28000	-
R06.01.09	R06.01.23	1	0.002	41	<1	10	37000	-
		3	0.002	35	<1	6	29000	0.00009
R06.02.15	R06.02.28	1	0.002	33	<1	2	27000	-
		2	<0.002	43	<1	<2	23000	0.00002
R06.03.05	R06.03.18	1	0.003	45	<1	9	28000	-
		2	0.002	32	<1	4	27000	-

(ばいじん、窒素酸化物、塩化水素、全水銀はO₂12%換算値)