

熱灼減量測定結果

採取場所：灰押し装置

採取日	号炉	測定結果（％）	備考
R04. 04. 04	1	4. 8	湿灰
	2	5. 7	湿灰
R04. 05. 09	1	6. 1	湿灰
	2	6. 7	湿灰
R04. 06. 07	1	6. 1	湿灰
	2	5. 2	湿灰
R04. 07. 04	1	4. 8	湿灰
	2	5. 3	湿灰
R04. 08. 01	2	4. 6	湿灰
	3	6. 0	湿灰
R04. 09. 05	2	3. 5	湿灰
	3	3. 8	湿灰
R04. 10. 24	2	5. 9	湿灰
	3	5. 6	湿灰
R04. 11. 08	2	4. 8	湿灰
	3	4. 4	湿灰
R04. 12. 05	1	6. 5	湿灰
	3	5. 8	湿灰
R05. 01. 12	1	6. 9	湿灰
	3	6. 7	湿灰
R05. 02. 06	1	5. 6	湿灰
	3	5. 2	湿灰
R05. 03. 13	1	5. 8	湿灰
	2	4. 8	湿灰